



**Jim Doyle, Governor**  
**Mary P. Burke, Secretary**

September 10, 2007

T.R.ARNOLD & ASSOCIATES  
CRAIG CRAFT  
700 E BEARDSLEY AVE  
ELKHART IN 46515

INDIANA BUILDING SYSTEMS  
STEVE BENSON  
51700 LOVEJOY DR  
MIDDLEBURY IN 46540

Re: Description: PREFABRICATED PLUMBING SYSTEM  
Manufacturer: INDIANA BUILDING SYSTEMS  
Product Name: MODULAR HOME PLUMBING SYSTEM  
Model Number(s): 2442RCU  
Product File No: 20070411

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2012.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 50 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum water supply fixture units (wsfu) on PEX tubing must not exceed 20.5 wsfu for 1-inch tubing, 11 wsfu for 3/4-inch tubing, 8 wsfu for 5/8-inch tubing, and 4 wsfu for 1/2-inch tubing.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE  
Plumbing Product Reviewer  
phone: 608-266-6742  
fax: 608-267-9566  
e-mail: mike.beckwith@wi.gov